

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-1157:109 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Digital Monitoring Products, 2500 N. Partnership Blvd., Springfield MO 65803
Contact: Terry Shelton (417) 831-9362 FAX (417) 831-1325

DESIGN: Synchronized or non-synchronized Strobe Lights. Models are as follows:

921-15W	922-15W	921-15C	*921-15CR
921-30W	922-30W	921-30C	*921-75CR
921-75W	922-75W	921-75C	*921-100CR
921-110W	922-110W	921-100C	
921-1575W	922-1575W		
921-MCW	922-MCW		
821	822		

RATING: Electrical: 10.5-31 VDC
Candela: 15cd, 15/75cd on axis, 30cd, 75cd, 100cd (ceiling), 110cd (wall)
Flash rate: 60 Flashes/minute

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. Models with suffix -W are for wall mount only. Models with suffix -C are for ceiling mount only. All models are for indoor use only.

MARKING: Listee's name, model number, electrical/candela rating and UL label.

APPROVAL: Listed as strobe lights suitable for the hearing impaired when used in conjunction with separately listed electrically compatible fire alarm control units. For indoor use only. For synchronization strobes, Models 831 and 832 Sync Control Module (CSFM Listing No. 7300-1157:107) must be used. Refer to listee's Installation Instructions Manual for details.

XLF: 7125-0785:141

*Rev. 04-10-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**